

Amy Ow

From: Jessica Henderson-McBean <JHenderson-McBean@swca.com>
Sent: Thursday, December 9, 2021 11:27 AM
To: Camille Leung
Cc: Kristen Outten; Amy Ow
Subject: Highland Estates Weekly Inspection Report 12/8/2021
Attachments: Inspection_Report_Form_12.08.21.pdf

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Hi Camille,

Please find attached the construction site inspection report for this month. When I was onsite yesterday there were a few site maintenance issues that I discussed with Bob. In particular, the trackout was getting pretty bad. Bob said he was going to order a street sweeper to come out yesterday.

Please let me know if you have any questions!

Thanks so much

Jessie Henderson-McBean | she, her, hers
Project Wildlife Biologist

SWCA Environmental Consultants
60 Stone Pine Road, Suite 100
Half Moon Bay, CA, 94019
O 650.440.4291 | C 805.712.8794



The contents of this email and any associated emails, information, and attachments are CONFIDENTIAL. Use or disclosure without sender's authorization is prohibited. If you are not an authorized recipient, please notify the sender and then immediately delete the email and any attachments.

From: Jessica Henderson-McBean
Sent: Thursday, December 9, 2021 11:17 AM
To: robertpellegrine@yahoo.com
Cc: cleung@smcgov.org; Kristen Outten <koutten@swca.com>; Amy Ow <aow@smcgov.org>
Subject: Highland Estates Weekly Inspection 12/8/2021

Hi Bob,

It was nice to see you at Highland Estates yesterday. Thank you for meeting with Tay and having her come out to document the status of the woodrat houses on Lots 9 and 10. As we discussed, please address the following action items ASAP. We have a large rainstorm in the forecast for Sunday and Monday.

1. Please repair the silt fence on Lot 11, which is protecting the riparian zone along the southern side of the property. Please also ensure that any drainage from the site is being directed to upland areas, and not being directed into the sensitive riparian zone.
2. Please sweep Cowpens Way and Cobblehill Rod as the street in both locations is overloaded with sediment and is causing trackout into the neighborhood.
3. Please re-install tree protection fencing on Lot 9. The oak trees on the southern side of the site have been hit by equipment and need to be protected from any further damage.
4. Please re-install silt fence that was removed on the downslope side of Lot 9 prior to the rain event this weekend.

Please let me know if you have any questions!

Thanks so much,

Jessie Henderson-McBean | she, her, hers
Project Wildlife Biologist

SWCA Environmental Consultants
60 Stone Pine Road, Suite 100
Half Moon Bay, CA, 94019
O 650.440.4291 | C 805.712.8794



The contents of this email and any associated emails, information, and attachments are CONFIDENTIAL. Use or disclosure without sender's authorization is prohibited. If you are not an authorized recipient, please notify the sender and then immediately delete the email and any attachments.